

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08386
Name of Facility: Miami Central Sr. High
Address: 1781 NW 95 Street
City, Zip: Miami 33147

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Dr. Dillon M. Williams Phone: 305-696-4161 ext 2415

Inspection Information

Purpose: Routine
Inspection Date: 9/9/2016

Begin Time: 11:50 AM
End Time: 02:00 PM

Additional Information

CENSUS	1813
FEMALES	784
MALES	1029

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	X 11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
X 9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
X 10. Provided/Accessible	21. Sewage Disposal	

General Comments

Please note: At time of inspection, maintenance and plumber were called and they are set to come and repairs the sinks and the urinal on Monday 9/12/16.

Email Address(es): dillon.williams@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #5. Maintenance & Repair Replace stained ceiling tiles in room 3214 Clean vents in bathrooms 9102, in bathroom 4101A to remove dust build up Provide missing ceiling tiles in corridor by gym Repair baseboard on wall located across from showers in male locker room CODE REFERENCE; Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.</p>
<p>Violation #9. Mechanical Ventilation Provide missing vent cover in restroom 3119C CODE REFERENCE: Mechanical Ventilation 64E-13.004(5)(d). All spaces which do not meet the requirements for natural ventilation shall be mechanically ventilated by means of electrically operated exhausts. Fans and blowers shall be sized and designed to provide the required air movement without excessive or disturbing noise. Special provisions shall be made in the design of ventilation systems in areas of high air contamination such as paint shops, auto repair shops and chemistry laboratories, art rooms where kilns are used, wood working, and metal shops, chemical storerooms. A high capacity emergency exhaust system is recommended for chemistry laboratories. All air conditioned spaces shall be ventilated when occupied.</p>
<p>Violation #10. Provided/Accessible Restore water at handwashing sinks in handicap stall of female restroom 2106 (work order MC39853), at handwashing sink in male locker rooms, at handwashing sink in handicap stall of restrooms 1141 & 1142 (work order MC39851), at handwashing sinks in male restroom 9102 (work order MC39849) Provide missing toilet seats in restroom 9106 Secure toilet seat in female restroom 6115 and all other applicable toilets throughout the facility CODE REFERENCE: Provided/Accessible 64E-13.004(6). Every school plant shall be provided with toilet and hand washing facilities for all occupants. These facilities shall be located for convenient student access and faculty supervision and kept clean and in good repair. Faculty and staff facilities shall be provided in separate rooms from student facilities.</p>
<p>Violation #11. Cleanliness & Repair Repair urinal in male restroom 2105 (work order in MC 39853) Seal sinks to their adjacent surface in female restroom 7103, in male restroom 9102 CODE REFERENCE: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.</p>
<p>Violation #19. Drinking Fountains Restore drinking water at fountains located next to bathroom 2106 Repair leak at fountain located next to bathroom 6115 Repair bottom of fountain located next to bathroom 9106 CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.</p>

Inspection Conducted By: Naissa Julien (31113)
Work: (305) 623-3500 ex. 24222
Date: 9/9/2016

Inspector Signature:

Client Signature: